

ATTACHMENT 9

TANK TABLES

Attachment 9
Tank Tables

Blend Liquids and Aqueous Liquids Tanks		
	volume (gallons)	level (feet)
overflow (100%)	29,395	23'2 9/16" (23.21')
compliance limit (-7")	28,628	22' 9 7/16" (22.63')
shut off (96.6%)	28,403	22' 5 9/16" (22.46')
alarm (92.7%)	27,240	21' 7" (21.58')

Small Sludge Tank		
	volume (gallons)	level (feet)
overflow (100%)	5679	10' 1" (10.08')
maximum level transmitter reading	4833	9' 6" (9.5')
compliance limit (-3")	4502	9' 3" (9.25')
alarm (3" below compliance limit)	4183	9' 0" (9.0')

Large Sludge Tank		
	volume (gallons)	level (feet)
overflow (100%)	33,538	33' 3" (33.25')
compliance limit (-7' 3")	25,348	26' 0" (26.0')
shut off (75%)	25,155	25' 10" (25.83')
alarm (70.2%)	23,550	24' 3" (24.25')